

PROFORMA - SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

CERTIFICATE NO- C/GKP/MAY-26/66

DATED- 15/05/26

It is certified that an inspection team headed by Assistant Engineer, Shashank Pandey from U.P. Jal Nigam Gorakhpur inspected the, Christuraja Public J.H. School Jungle Jhahhawa, Ward-No.10, Peppeganj, Gorakhpur on 11/05/2026 and on the basis of Water Test Report (Attached) bearing no C/GKP/May-26/66 dated 15/05/2026 of District Level Water Analysis Laboratory Jal Nigam Gorakhpur (PHED Lab) certified that Christuraja Public J.H. School Jungle Jhahhawa, Ward No.10, Peppeganj, Gorakhpur has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school as per the norms prescribed by the Central/ State/ U.T. Govt.

The above valid for a period of 15/05/2026 to 14/10/2026

Name :- Shashank Pandey

Designation:- Assistant Engineer

Signature With Seal :-

  
Assistant Engineer  
10th Division, U.P. Jal Nigam  
GORAKHPUR

To,  
Manager  
Christuraja Public J.H. School,  
Jungle Jhahhawa, Ward No.10,  
Peppeganj, Gorakhpur



**District Level Water Analysis Laboratory,**  
**U.P. Jal Nigam (Rural), Gorakhpur**  
Address: EWS 388,389,390 Rapti Nagar Phase-1, Medical Road,  
Gorakhpur(U.P)-273003

**Water Test Report**

**Format No-7.8 F-01**

Report No.	C/GKP/MAY-28/66	Report Release Date	15/05/2026	Page No:	1
ULR No.	—	Quality of Sample	Drinking Water		

**Customer Details**

Office Name and Address	Christuraja Public J.H. School Jungle Jhajhawa, Ward No.10,Pepeganj,Gorakhpur				
Ref Letter No.& Date	07/05/2026				

**Basic Details of Sample**

District	Gorakhpur	Tehsil/Block	—
Gram Panchayat	—	Village	—
Habitation	—	Location	Christuraja Public J.h School Jungle Jhajhawa, Ward No.10, Pepeganj, Gorakhpur
Source of Sample	R.O	Sample Code	C/26/05/13
Quantity of Sample	1000 + 500 ml	Date of Sample Collection	11/05/2026
Receiving Date	11/05/2026	Sampling Done By	Svatantra Kumar
Sampling Method Used	APHA 24 <sup>th</sup> Ed 1060 B	Sampling Method Plan	UPJN(R)/QSP/02/2.9
Analysis Start Date	12/05/2026	Analysis Completion Date	12/05/2026

**Environmental Condition**

Temperature	25°C±3°C	Humidity	50%±15%
-------------	----------	----------	---------

**Technical Date of Analysis**

Sr. No	Analysed parameters	Unit	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Odour	—	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5 ):2018
2	Taste	—	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8 ):2023
3	Turbidity	NTU	0.35	1	5	IS 3025 (Part 10):2023
4	pH @( 25°C)	—	7.16	6.5-8.5	No relaxation	IS 3025 (Part 11):2022
5	Total Dissolved Solids (TDS)@( 180°C)	mg/L	90	500	2000	IS 3025 (Part 16) :2023
6	Total Hardness ,(as CaCO <sub>3</sub> )	mg/L	62	200	600	IS 3025 (part 21) :2009
7	Total alkalinity, (as CaCO <sub>3</sub> )	mg/L	76	200	600	IS 3025( Part 23):2023
8	Chloride ,(as Cl <sup>-</sup> )	mg/L	18	250	1000	IS 3025(Part 32):2025
9	Calcium,(as Ca <sup>+2</sup> )	mg/L	12.4	75	200	IS 3025(Part 40): 2024
10	Magnesium,(as Mg <sup>+2</sup> )	mg/L	7.5	30	100	IS 3025(Part 46): 2023
11	Sulphate ,(asSO <sub>4</sub> )	mg/L	2.198	200	400	APIHA 24th Edition 4500-SO <sub>4</sub> Method E Turbidimetric Method 2023
12	Nitrate ,(as NO <sub>3</sub> )	mg/L	BDL	45	No relaxation	APIHA 24th Edition 4500-NO <sub>3</sub> Method B UV Screening Method 2023
13	Iron ,(as Fe)	mg/L	BDL	1	No relaxation	APIHA 24th Edition 3500-Fe Method B Phenanthroline Methods 2023
14	Fluoride, (as F)	mg/L	0.190	1.0	1.5	APIHA 24th Edition 4500-F Method C ( Electrode Method) :2023
15	Arsenic	mg/L	BDL	0.01	No Relaxation	APIHA 24th Edition 3500 -As Method B (Silver Diethyldithiocarbamate Method):2023

#BDL- Below Detection Limit, NA- Not Analysed

\*\* Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
  2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
  3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  4. Sample will be stored up to 7 days (in case of non - perishable items only) from the date of issue of tests reports unless otherwise Specified.
  5. Sample collected by the laboratory.

*Vishal Mondal*  
Review By



Laboratory Contact details: Email-labgorakhpur@gmail.com Contact - +91-9889105748

\*\*\*\*\* END OF THE ANALYSIS REPORT\*\*\*\*\*



# District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Gorakhpur

Address: FWS 388,389,390 Rapti Nagar Phase-I, Medical Road, Gorakhpur(U.P)-273003

## BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No	LC/GKP/MAY-26/66	Date:	15/05/2026	Page No	1/1	
<b>Customer Details</b>						
Office Name and Address	Christuraja Public J.H. School Jungle Jhajhawa, Ward No.10,Pepeganj,Gorakhpur					
Ref Letter No & Date	07/05/2026					
<b>Basic details of sample</b>						
District	Gorakhpur	Block	-			
Gram Panchayat	-	Village	-			
Habitation	-	Location	Christuraja Public J.h School Jungle Jhajhawa, Ward No.10, Pepeganj, Gorakhpur			
Water Source	R.O	Sample Code	B/26/05/13			
Quantity of Sample	250 ml	Date of S.C.	11/05/2026			
Receiving Date	11/05/2026	S. Collector	Svatantra Kumar			
Sample Depositor	Svatantra Kumar					
Analysis Start Date	12/05/2026	Analysis Completion Date	14/05/2026			
<b>Technical Data of Analysis</b>						
Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH ( 25°C ± 2°C )	7.16		6.5-8.5	No relaxation	IS 3025 (Part 11):2017
2	Residual Chlorine	0	mg/L	0.2	1.0	IS 3025 ( PART 26 ) : 1986
3	Total Coliform	0	CFU	0	CFU	APHA 24 <sup>th</sup> Edition :2023
4	E. Coli	0	CFU	0	CFU	APHA 24 <sup>th</sup> Edition :2023
<b>Result : Satisfactory</b>			<b>Remark: Potable</b>			
Note 1. This Certificate refers only to the particular sample(s) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has. 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.						
Analysed By <i>Sandhya Verma</i>			Authorized Signatory <i>Sandhya Verma</i>			

Laboratory Contact details: Email-labgorakhpur@gmail.com

Contact - +91 8604561988

-----End of the Report-----